

TECHNICKÝ SKÚŠOBNÝ ÚSTAV PIEŠŤANY, š.p. Certifikačný orgán certifikujúci výrobky Krajinská cesta 2929/9



921 01 Piešťany, Slovenská republika

CERTIFICATE

No. TSU 010-12

Collector Type:

Flat plate solar collector

Model:

TS 300; TS 250; TS 500

Company:

THERMO/SOLAR Žiar s.r.o., Na vartičke 14, 965 01 Žiar nad Hronom,

Slovak Republic

Production site:

THERMO/SOLAR Žiar s.r.o., Na vartičke 14, 965 01 Žiar nad Hronom,

Slovak Republic

This certificate confirms that the product complies with the requirements of

EN 12975-1:2006+A1:2010

Specific CEN Keymark Scheme Rules for Thermal Products, version 28.00

and the company is granted the licence for the right to use the mark



in conjunction with the No. of this certificate.

Date of first issue:

06.12.2012

Date of last renewal: 03.10.2016

Validity until:

29.09.2021

Ing. Dušan Hanko Head of Product Certification Body

Technical data

The summary of the test results is listed in the data sheet – see Annex to this certificate.

Test methods: according to EN 12975-2:2006

Test results: Test Report No. 110700001/1/PQ dated 30.09.2011

Test Report No. 120700004/1/P dated 03.12.2012
Test Report No. 120700004/2/P dated 03.12.2012

Note:

- The freeze resistance test according to EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's safety instructions, in regions exposed to frosts a premixed antifreeze have to be used.
- The optional impact resistance test according to EN 12975-2, clause 5.10 was not carried out.

